

Application Detail (Renewal)

IUID: 85832152	Email: bhojiadental@gmail.com	Mobile No: 9816027721
Application ID: 123339	Registration No: HP-FIRE/49605	Application Submission Date: 14-06-2025

General

Name of Fire Division/Home Guard Battalion: 11th Battalion Solan	Name of Fire Station: FS Baddi
---	---------------------------------------

Enterprise Detail

Enterprise Name: Bhojia Vidyapeeth	Location of the Building: Baddi	Type of Construction: RCC
District: Solan	City/Town: Baddi	PIN Code: 173205
Corresponding Address: Village Bhud P.O. Baddi Tehsil - Baddi Distt. Solan (HP) 173205		

Details of M.D./Managing Partner/CEO/Lead Promoter/Proprietor (This detail will be used for all communication in future)

Full Name: Vikram Bhojia	Email: bhojiadental@gmail.com	Mobile Number: 9816027721
Category: D-3	Designation: Chairman	

Others

Site/Location: Baddi	Type of Occupancy/Project to be constructed (Hotel/Industry/School etc.): School
Whether the Fire and Life Safety measures/norms laid down in N.B.C. Part-IV shall be adopted during construction?: Yes	

Plot Details

Plot Area (Sq mtrs): 4210	Covered Area (at ground level in Sq mtrs): 1629.82	Total Covered Area (sq mtrs): 6154.74
Height of building (mtrs): 20.02	Nos of floor: 5	

Business Details

Type of Business: School	No. of the Workers/Officials: 700	Mode and Type of Production: Electercity
Detail of insurance, if any: NA	List of raw material: NA	Name of finished product: NA

Electrical wiring system: U/G	Sanctioned electrical load: 5 KW	Distance from nearest Fire Station (in Kms):3
-------------------------------	----------------------------------	---

Details of First Aid Fire Fighting equipment/extinguishers already installed within the premises

Type of Extinguishers	capacity	Qty:	Make	Serial No	mfg Year	Purchase Date:	Remarks
ABC	5 kg	05	Omex	000	2021	2021-03-15	List Attached

Fixed Fire Fighting Installation

Yard Hydrants/Landing Valve: No	Down comer: No	Automatic Sprinkler system: No
Manually operated Electric Fire Alarm System: Yes	Delivery Hoses: No	Riser: No
Hose Reel: Yes	Automatic Detection and Alarm System: Yes	Deluge valves & Monitors etc.:No
Emergency Branch etc:No		

Water Supply System Details

Under Ground Static Water Storage Tank capacity: 50 KL	Terrace Tank with Capacity: 20 KL	Water Source: Borewell
Main Pump: NO	Jockey Pump : NO	Stand by Pump: NO
Pump at Terrace Level: 900 lpm		

Other Details

Details of Safety Equipments, if any i.e. Protective Suits, Entry Suit, B.A. Set etc.: NO
Whether the workers/other staff are well conversant with the operation of first aid fire fighting equipments installed in the premises?: Yes
Detail of flammable and hazardous materials alongwith Physical and Chemical data: NO
Whether P.A. System is installed?: Yes
Other Information: As per your recommendation we are installed the fire hose reel in school premises

Application History

Authority Role	Remarks/Comment	Action Date
----------------	-----------------	-------------

Applicant	Application submitted successfully.	14 Jun, 2025 12:11 PM
-----------	-------------------------------------	-----------------------

Concern Department History

Department	Remarks/Comment
------------	-----------------





Single Window Clearance System

Directorate of Industries(DOI)
Govt. of Himachal Pradesh

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

NO OBJECTION CERTIFICATE

TO WHOM IT MAY CONCERN

That the premises of **Bhojia Vidyapeeth Village Bhud P.O. Baddi Tehsil - Baddi Distt. Solan (HP) 173205** was inspected on 2023-05-30 with reference to his application No. App/04/12/23/8/298 dated 2023-04-12 15:26:00 by the incharge Fire Station FS Baddi with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years w.e.f. **06/2023 to 01/06/2025** subject to fulfilment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named appicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire services.
4. Good House keeping must be maintained within the premises.

हिमाचल प्रदेश सरकार

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.

[Digitally Signed 02-06-2023 16:03:04]

Chief Fire Officer.
Himachal Pradesh Shimla-2

Place: Shimla

Dated: 2023-06-02